

CERTIFICATE OF STABILITY

FORM – C

Form of certificate of structural soundness under sub section – 4 of the Tamilnadu Public Building (licensing) Act (Tamil Nadu Act 13 of 1965 referred to in rule of the Tamilnadu public Building (Licensing) rule 1965.

I certify that I have inspected the building mentioned in the statement and furnish below its salient technical features.

1) Foundation:

- | | | |
|---|---|--|
| i. Depth below ground level | : | 1.80 M |
| ii. Nature of soil met with at foundation level | : | Hard Gravel Soil at 1.50 M below ordinary soil |
| iii. Pressure at foundation | : | 18.62 tones/sqm |
| iv. Probable safe bearing capacity of the) of the soil met with at foundation | : | 25 tones/sqm |

2) Superstructure:

- | | | |
|--|---|--|
| i. Maximum stress in the most critical section of masonry and concrete | : | 20.35 tones/sqm |
| ii. Nature of masonry and concrete and its safe permissible stress | : | Brick Masonry in Cement Mortar - 45 tones/sqm.
RCC Member = 20 N/ Sqm |

The Structural Soundness of the building has been verified by me with reference to ISI loading standards 875 (latest version) and other relevant Indian standards code of practice and declare that the building for the purpose noted in the statement , A license may be granted for the period of 3 Years from **07.03.2022 To 06.03.2025**.

Date: 15.02.2022

Signature of the Engineer

Ln. Er. A. VENKATACHALAM, M.E., M.Sc., (TV) MIE, RV,
CHARTERED ENGINEER, REGISTERED VALUER-04/05-06
DISTRICT PANEL ENGINEER CLASS -1A,
APPROVED VALUER FOR BANKS,
ARRUL ASSOCIATES,
29/57, Salem Road, Namakkal-637 001,
Cell : 98427 57507, 98427 33924


STATEMENT TO ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS

Location of the Building Door no, street, and Name of place	Age of the Building	Number of Stories	Short description of Structures Steel/RCC Framed/ Load bearing Masonry	Purpose for which the Building is certified to Use	The Period for which the building will be Structurally sound	Number of persons to be accommodated
(1)	(2)	(3)	(4)	(5)	(6)	(7)
"GREEN WORLD EXCEL SCHOOL", Namagiripettai Village, Rasipuram Taluk, Namakkal District.	G.F -2010 (12 Years) F.F- 2011 (11 Years)	Ground & First Floor Only	RCC Framed Structure	Class Rooms, Lab, Library & Toilet Block for Green World Excel School Purpose	3 Years from 07.03.2022 To 06.03.2025	Students- 720 No's + Staff - 30 No's

This certificate will not hold good in case of natural calamities such as fire, flood and Earthquake.

This certificate is not valid if the Applicant makes any Additions (or) modifications without prior Approval.

Date: 15.02.2022


Signature of the Engineer

Ln.Er.A.VENKATACHALAM, M.E., M.Sc. (RV) MIE, FV.,
CHARTERED ENGINEER, REGISTERED VALUER-04/05-06
✓ DISTRICT PANEL ENGINEER CLASS -1A, ✓
APPROVED VALUER FOR BANKS,
ARRUL ASSOCIATES,
29/57, Salem Road, Namakkal-637 001.
Cell : 98427 57507, 98427 33024